Electrical Safety



Inspection Checklist				
Location:				
Name of Inspector(s):				
Date of Inspection:				
Inspection Items	✓	Corrective Action Planned	Who is Responsible	Action Date
Circuit boxes are kept clean, are not exposed to leaks or water, and are marked with clear signs.	☐ Yes ☐ No ☐ N/A			
Light fixtures are kept clean, and are not exposed to leaks or water.	☐ Yes ☐ No ☐ N/A			
Extension cords are not being used as long-term wiring.	☐ Yes ☐ No ☐ N/A			
All extension cords are suitable for heavyduty use, and are in good condition.	☐ Yes ☐ No ☐ N/A			
All electrical tools have either a three- prong cord or are clearly marked as "double-insulated."	☐ Yes ☐ No ☐ N/A			
All electrical cords and connections are well out of the reach of animals.	☐ Yes ☐ No ☐ N/A			
Ground fault circuit interrupters (GFCIs) are installed at all outdoor receptacles, in washrooms, and in all other damp or wet locations.	☐ Yes ☐ No ☐ N/A			
Overhead power lines allow a clearance of at least ten feet from all farm equipment or machinery that may pass underneath; overhead power lines are clearly marked.	☐ Yes ☐ No ☐ N/A			
At least one ladder on the farm is made of non-conducting wood or fiberglass for work around electrical fixtures.	☐ Yes ☐ No ☐ N/A			
Other Notes:				



