

Inspection Checklist: Electrical Safety

Company Name:	
Workplace Location:	
Name of Inspector(s):	
Date of Inspection:	
Inspection Items	
Circuit boxes are kept clean, are not exposed to leaks or water, and are marked with clear signs.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:
	Action Date:
Light fixtures are kept clean, and are not exposed to leaks or water.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:
	Action Date:
Extension cords are not being used as long-term wiring.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:
	Action Date:
All extension cords are suitable for heavy-duty use, and are in good condition.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:
	Action Date:
All electrical tools have either a three-prong cord or are clearly marked as “double-insulated.”	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:
	Action Date:
All electrical cords and connections are well out of the reach of animals.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:
	Action Date:
Ground fault circuit interrupters (GFCIs) are installed at all outdoor receptacles, in washrooms, and in all other damp or wet locations.	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

Corrective Action:	Who is Responsible:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	Action Date:	
Overhead power lines allow a clearance of at least ten feet from all farm equipment or machinery that may pass underneath; overhead power lines are clearly marked.		<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	Action Date:	
At least one ladder on the farm is made of non-conducting wood or fiberglass for work around electrical fixtures.		<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	Action Date:	
		<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	Action Date:	
		<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
Corrective Action:	Who is Responsible:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
	Action Date:	
Other Notes:		